

ENDRESS
Together, always on.

ESE 606 DHS-GT ES

Order No. **112308A**

Main features	
Alternator type	synchron
Max. Output 3~ [kVA/kW]	7.5/6.0
Max. Output 1~ [kVA/kW]	4.0/3.6
Continuous Power 3~ [kVA/kW]	5.9/4.7
Continuous Power 1~ [kVA/kW]	3.7/3.3
Nominal voltage [V]	400/230
Nominal Current [A]	7,5/15,9
Power factor cos (phi)	0,8/0,9
Frequency [Hz]	50
Protection Class [IP]	23

Engine	
Engine Type	HONDA GX390 / 11 HP
Design	1-cylinder 4-stroke OHV
Displacement [ccm]	389
Output 3000 rpm	6,4
CO2 emissions [g / kWh]	743
CO2 test procedure	k.A
Fuel	Petrol
Fuel tank capacity [l]	30
Running time @ 75% PRP	15,8
Starting system	Electric starter
Sound power level LWA [db(A)]	97
Sound pressure level LPA (7 m) [db(A)]	72
Weight in kg ca.	86
Dimensions L x W x H [mm]	800 x 538 x 576
Shockproof sockets	1 x 230 V/16 A
	1 x CEE 230 V/16 A
	1 x CEE 400 V/16 A

This CO2 measurement results from testing over a fixed test cycle under laboratory conditions a(n) (parent) engine representative of the engine type (engine family) and shall not imply or express any guarantee of the performance of a particular engine'.

Power ratings according to ISO 8528-1: 2005

Technical data and illustrations are not binding. We assume no liability for misprints.

2026-10-12

ENDRESS Elektrogerätebau GmbH
Neckartenzlinger Str. 39
D - 72658 Bempflingen, Germany

Phone.: +49 (0) 7123-9737-0
Fax.: +49 (0) 7123-9737-50
www.endress-generator.com

ESE 606 DHS-GT ES

Order No. 112308A

Equipment features
Lack of oil automatic switch-off
Alternator overload protection
Honda OHV engines
Large fuel tank for long running times
Compound regulated high performance generator
Remote start connection

Possible applications	400V	230V
Electronic consumers up to	5500W	3100W
Electric tools up to	3700W	2100W
Garden equipment up to	2800W	1600W
Inverter welding equipment up to a dia. of 3.25 mm		

Special equipment - not retrofittable	Order No.
RCD protection switch incl. earthing kit	162 352

Accessories	Order No.
Wheel kit	**161 000**
Wireless remote control	162 024
Maintenance kit	**164 029**

laboratorio-olosuhteissa tehdyssä kiinteässä testisyklissä, eikä se ole tae yksittäisen moottorin suorituskyvystä".

Power ratings according to ISO 8528-1: 2005

Technical data and illustrations are not binding. We assume no liability for misprints.

2026-10-12

ENDRESS Elektrogerätebau GmbH
Neckartenzlinger Str. 39
D - 72658 Bempflingen, Germany

Phone.: +49 (0) 7123-9737-0
Fax.: +49 (0) 7123-9737-50
www.endress-generator.com